

TRANSMITTAL

DATE: August 24, 2010  
TO: Environmental (1)  
JCSA (1) (2)  
Fire (1)  
FROM: Leanne Reidenbach, Senior Planner  
SUBJECT: SP-0061-2010, Busch Gardens 2011 Germany Attraction (resubmittal)

Environmental Division

AUG 24 2010

RECEIVED

ITEMS

ATTACHED: Site plan  
Comment response document  
Supporting engineering documents (1)

ACTION: Please review and return comments by **September 6, 2010**.

NOTES: **Subject to conditions associated with HW-0002-2010.**

The following changes were made since the 1<sup>st</sup> submittal:

- Building 20 was removed and services moved to an enlarged Building 10
- Building 50 increased in size by 215 sq ft
- Building 30 was removed
- Building 10 lift station has been directed to a 6" gravity line
- Building 10 downspouts have been collected into the onsite storm system

**EXPEDITED REVIEW**

Plan is approved by the Environmental Division. A Land-Disturbing Permit and Siltation Agreement, with surety, is required for this project. Stormwater Facility inspection fees are not required as storm drains systems are minor private yard drainage type applications; therefore an Inspection/Maintenance is also not required. Registration for a state VSMP general permit for construction activities is required through the Virginia DCR.

0.98 AC. Disturbed  
JR watershed  
HVC Code JL35

*[Signature]*  
09-02-10